

Your Strips Comfort is a Z-Wave multi-sensor that can be added to any certified Z-Wave system and operate with any Z-Wave device.

Strips Comfort is a discreet temperature and light sensor.

Strips Comfort has a range up to 40 meters. The range can be extended by using any non-battery Z-Wave device, which automatically acts as a repeater when placed between Strips Comfort and the controller.



Visit www.sensative.com/comfort to find out more, including instructional videos or for any support inquires.

Strips Comfort will now report sensor levels and alarms according to the set configuration (see table A on the backside).

The Comfort kit includes a mounting plate that can be used for hanging Strips Comfort on the wall with screws.

Mounting Strips Comfort

You may mount Strips Comfort directly on the wall using Strips Comfort's adhesive (ALT. A), or use the mounting plate (ALT. B):

ALT. A

Avoid placing Strips Comfort directly on metal as it affects the range.

Note that Strips Comfort's adhesive is strong and can affect the surface if it is removed.

- A 5** Remove the protective tape from Strips Comfort adhesive.
- A 6** Place Strips Comfort on the wall.

Your Strips Comfort is now mounted and added to your Z-Wave system. It will give you valuable sensor data that may be used for alarms or controlling other devices.

Please note that poor network reliability will affect Strips Comfort's battery life. When Strips Comfort blinks 5 times, this indicates that Strips Comfort failed to communicate with the controller. If it happens frequently you may move the controller closer or add an extender between the controller and Strips Comfort.

Enjoy Strips Comfort for years to come!

Need help? Contact Support@sensative.com

You may configure Strips Comfort to better support your needs using the configuration parameters (see Table A on the backside).

Z-Wave is an international standard for wireless communication in smart homes and buildings, enabling you to monitor and control your home remotely.

Strips supports association group 1 (lifelink). Max 1 node.

Strips uses low power (< 2 dBm) radio signals to communicate with your Z-Wave controller.

The radio frequencies used are: 868.42/869.85 MHz (EU), 908.4/916.0 MHz (US/Can)

Adding Strips Comfort to your Z-Wave system (Figure 1-4)

Strips Comfort comes in auto-add mode. Follow the process below to add Strips Comfort to your network:

- 1** Set your Z-Wave controller in add mode. See your controller's manual.
- 2** Keep Strips Comfort near its intended location during the add process. Remove the magnet from Strips Comfort.
- 3** Your Z-Wave controller application should now add Strips Comfort.
- 4** You may verify that your controller shows Strips Comfort reporting correctly by exposing it to a light source for 5 minutes.

Note: Strips auto-add mode is started when the magnet is removed for the first time out of the box. If your Strips did not get added with auto-add, use the wake up command to add.

ALT. B

- B 5** Mark holes for the screws using the mounting plate.
- B 6** Drill 4 mm diameter holes, place the plugs, and mount the screws included in the kit.
- B 7** Remove the protective tape from Strips Comfort's adhesive.
- B 8** Mount Strips Comfort on the marked "Strips side" of the plate.
- B 9** Hang your Strips Comfort on the screws so that it can be removed again if needed.

How Strips Comfort reports temperature and LUX

Temperature reporting.

1. When a temperature alarm is triggered, according to parameters 6, 7 & 8
2. When the temperature has changed more than 2°C since last report was sent
3. Following the rules of configuration parameter 3

When configuration parameter 3 is set to Normal (1): Temperature will report when change is more than 1 degree since last report & more than 1 hour has passed. Device will also report at least once every 24 hours.

When configuration parameter 3 is set to Frequent (2): Temperature will report when change is more than 0.5 degree since last report & more than 15 minutes have passed. Device will also report at least once every 6 hours.

Ambient Light Reporting (1-64 000 LUX)

Strips will report when the Lux value is double or half of the previous sent value. Device will also report at least once every 24 hours.


For more details visit : www.sensative.com/comfort

A) CONFIGURATION PARAMETERS

No.	Description	Values	Default
2	LED alarm event reporting (1 byte)	0: Off 1: On	1
3	Temperature & Light reporting frequency (1 byte)	1: Normal 2: Frequent	1
4	Temperature reporting (1 byte) (Does not affect temperature alarms)	0: Off 1: On	1
5	Temperature reporting unit (1 byte)	0: Celsius 1: Fahrenheit	0
6	Temperature alarms (1 byte)	0: Off 1: On	0
7	High temperature alarm level (1 byte)	-20 to +60 (degree C)	60
8	Low temperature alarm level (1 byte)	-20 to +60 (degree C)	-20
9	Ambient light reporting (1 byte)	0: Off 1: On 2: Report only when levels defined in parameter 10 & 11 are passed.	1
10	High ambient light report level (4 bytes)	3 - 64 000	40 000
11	Low ambient light report level (4 bytes) (Must be significantly lower than parameter 10)	1 - 42 000	5 000
12	Leakage alarm (1 byte)	0: Off 1: On	0
13	Leakage alarm level (1 byte)	1 to 100 (1 = almost dry, 100 = wet)	10
14	Moisture reporting period (1 byte)	0-120 (Hours between reports)	0 (Off)

Note: Comfort still supports moisture functionality. Moisture sensors and alarms may appear after adding Strips Comfort.

TEMPLATE FOR DRILLING



B) LED LIGHT SIGNALS

1 short blink	Seen when doing user commands (Table C) or alarm event - when Strips is added in network.
2 short	Seen when doing user commands (Table C) - when Strips is not added in a network.
1 long	Indicates successful transmission of user commands (Table C)
5 short	Error (E.g. communication with controller failed)


C) USER COMMANDS

Wake up	Wake up Strips manually for Z-Wave communication. Move the magnet to the rounded edge, and once the LED blinks, move the magnet away (See figure below). Repeat two more times within 10 seconds. A successful wake-up is confirmed with one LED blink.
Add/remove	Set your controller to add/remove mode (see your controller's manual). Then follow the instruction above for the "Wake up" command.
Reset	You may need to reset Strips if your Z-Wave controller is missing or not responding. Follow the instructions for "Wake up" above, but on the 3rd repetition, leave the magnet over the user command sensor as seen below, for 10 seconds.

In order to send commands, hold the magnet in the position you see below and move it over the user command sensor (LED will signal), then move the magnet away. Repeat this according to the user command directions (Table C) of the command you want to send.

OTHER

Wake up time	Strips wake up time is set to 24 hours by default, it is possible to change this value between 30 minutes and 24 hours but this will affect battery life.
Association	Strips supports association group 1 (lifeline). Max 1 node. Normally used to send Strips' status to the Z-Wave controller.



110 mm